



Inspection certificate  
Sertifikat o kontrolisanju

**SERTIFIKAT O KONTROLISANJU**  
**INSPECTION CERTIFICATE**

Broj / Number: T 1939  
Strana / Page: 1 / 1

**Na zahtev naručioca /**  
*By the request of purchaser:* **SLOVARM d.o.o. ul.: Autoput I-13, Blok 53 b.b. 11070**  
**Novi Beograd /Serbia**

**preduzeto je/**  
*set to:* kontrolisanje novog proizvoda /  
*the new product inspection*

**u vezi sa Izveštajem o kontrolisanju /**  
*in relation to Inspection report:* Broj / Number: T 1939

**sa dokumentima u prilogu/**  
*with enclosed documents:*

- Izveštaji o ispitivanju C 1904/  
- Test reports C 1904;
- Dokumentacija o proizvodu /  
Product documentation.

**INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:**  
*INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:*

**predmet kontrolisanja /**  
*the inspection object:* **SANITARNE JEDNORUČNE BATERIJE / SANITARY**  
**HAND MIXER TAPS**

**proizveden od /**  
*manufactured by:* **SLOVARM a.s. Dolná 1259/2 90701 Myjava,**  
**SLOVAKIA**

**oznaka - tip - serija /**  
*mark - type - series:* **Lobelia (EN), Ficaria (EF), Gloria (EG) i Densa (ED)**

**kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /**  
*as specified in the Annex A, meets the requirements as described in:*

**referentnom dokumentu /**  
*reference document:* **SRPS EN 200:2010.**

**Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .**  
*The inspection certificate is issued on the basis of the standard SRPS ISO/IEC 17020:2012 .*

**Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa**  
**periodičnim kontrolisanjem do dana /** 08.11.2024.  
*Surveillance of the inspection object compliance is assured by periodical*  
*inspection until the date:*

detaljno oznaka - tip - serija /mark - type - series specification :	kratak opis / short description :	tehničke karakteristike / technical characteristics :
<b>Lobelia (EN)</b> <b>Ficaria (EF)</b> <b>Gloria (EG)</b> <b>Densa (ED)</b>	kada	$P_{rad}=5 \text{ bar}$ $T_{max}=65^{\circ}\text{C}$
	lavabo st.	
	lavabo zidna	
	sudopera st.	

**izdat od / issued by :**

**mesto, datum / place, date:**

Beograd, 08.11.2019



**RUKOVODIOCA CENTRA ZA GASNU TEHNIKU**  
**GAS TECHNIQUE CENTRE MANAGER**

Kristina Petković, dip. maš. inž.

Ime, Prezime / Name, Surname